Kitemark™ Certificate

No. KM 60983

BS EN 12608-1 : 2016 + A1:2020 / PAS 24:2022 - Enhanced security performance requirements for doors in the UK.

This Certificate covers the following door system design specification. The following materials are also certificated for use with doors in conjunction with BS 7412 and PAS 24 when foiled in accordance with BS 7722:2010: Only those components that have been approved in accordance with the Kitemark scheme requirements can be incorporated within the system(s) detailed.

Omnia PVC-U Residential & French Door System

Fabricated and installed in accordance with the latest issue of the following Veka plc-controlled manual(s):

Veka Imagine Omnia Fabrication Manual.

System description:
The door assemblies are single or double leaf, open in or open out, glazed in, double or triple glazed with at least one pane of laminated glass meeting the requirements of BS EN 356:2000, Class P1A or higher, where applicable, and shall be glazed in accordance with the BS 6262 series, with or without midrail and/or letterplate which meets the requirements of TS008:2015 Enhanced Security Grade 2, and a handle and cylinder or cylinder guard combination achieving a minimum 3* in accordance with TS007. With mechanically fixed 101436 or 104137 Aluminium low thresholds or of fully welded construction. Doors are classified as D.

The fitting of any connected or smart device to this product will invalidate this Kitemark Certificate unless BSI has been provided with objective evidence from a competent authority that the sensor has been tested and certified to EN 303645. BSI will update any Kitemark certificates with the relevant products as and when they have been tested.

Hardware Options

Lock
Maco C-TS Top Hat 2 HoBo (master)
Maco C-TS (slave)
Yale Lockmaster 21 YL21S-35H-172-27 (master)
Yale Lockmaster YLS312-35S-27 (slave)
ERA 3 Hook Roller 35-MPL

Hinge
SFS Dynamic 3DF
ERA Omnia Door
GT Quad Guard Hinge Protectors
Mila ProSecure Flush

Glazing
GT Securi-Clips, GT Snap-Lok

First Issued: 2002-04-09
Latest Issue: 2025-12-12

Effective Date: 2025-12-12
Expiry Date: 2027-08-28

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

BSI Assurance UK Limited, registered in England under number 7805321 at Seventh and Eighth Floors, The Acre, 90 Long Acre, London, WC2E 9RA, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 60983

Omnia PVC-U Residential & French Door System
Size Limitations and Performance Characteristics

Door Type	Length (mm) - Maximum	Height (mm) - Maximum (including sill)	Air Permeability classification	Watertightness classification	Resistance to Wind classification	Exposure category as given in Table 1 of BS 6375-1
Sash dimensions for doors with approved outer frame and sash profiles:						
Double leaf open out PVC threshold	1122	2122	2	4A	B3	1200
Single leaf open in PVC Threshold	1122	2122	2	5A	C3	1200
Single leaf open in low threshold (104136)	1122	2122	2	2A	C3	1200
Single leaf open in low threshold (104137)	1122	2122	2	4A	C3	1200
Double leaf open out low threshold (104136)	1122	2122	3	2A	A3	800

Classification for Operational strength in accordance with BS 6375

Operating forces	Class 2
Vertical Load	Class 2
Resistance to Static Torsion	Class 2
Soft and Heavy body Impact	Class 2
Hard Body Impact	Class 2
Load Bearing capacity of safety devices	N/A
Closure against obstruction	Pass
Resistance to opening and closing	Class 4 /2

First Issued: 2002-04-09
Latest Issue: 2025-12-12

Effective Date: 2025-12-12
Expiry Date: 2027-08-28

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

BSI Assurance UK Limited, registered in England under number 7805321 at Seventh and Eighth Floors, The Acre, 90 Long Acre, London, WC2E 9RA, UK.
A member of BSI Group of Companies.